



Generator Set GS 6-1 (Cirrus 1)

Subsea Handbook List of Generators

Original Supplier	Kolfor Plant Ltd
Year of Manufacture	1985
Serial No	CR 381
Model	1793
Alternator Model	Newage MSC434E
Rated Power - Continuous	250 kVA, 200 kVA @ 0.8 pf
Rated Voltage	415 / 240 V
Phase	3
Frequency	50/60 Hz
Rated Current	348 A
Rated RPM	1500 / 1800
Engine Type	Cummings NT855G3
Running Hours	15179
Overall Size	3.95L x 1.76W x 2.4H
Weight	5000 kg
Present Location	Batam Depot

